

**CHECK LIST FOR STATIONARY LPG INSTALLATION PROPOSALS**

Application received: Date \_\_\_\_\_

Installation File Name \_\_\_\_\_

Installer's License No. \_\_\_\_\_ Expiration date \_\_\_\_\_ Qualified Installer YES  NO

Filing Fee Rec'd  \$50 PCN \_\_\_\_\_ Resub. Fee Rec'd  \$30 PCN \_\_\_\_\_

Type of Installation: \_\_\_\_\_

Aggregate WC of **current** storage \_\_\_\_\_ Number of tank(s) to be installed \_\_\_\_\_

Size of tank(s) to be installed \_\_\_\_\_ Total WC upon completion \_\_\_\_\_

Container Information complete YES  NO

Mfg's Name: Tank 1 \_\_\_\_\_, Tank 2 \_\_\_\_\_, Tank 3 \_\_\_\_\_

Serial No.: Tank 1 \_\_\_\_\_, Tank 2 \_\_\_\_\_, Tank 3 \_\_\_\_\_

Water Capacity: Tank 1 \_\_\_\_\_, Tank 2 \_\_\_\_\_, Tank 3 \_\_\_\_\_

Year Built: Tank 1 \_\_\_\_\_, Tank 2 \_\_\_\_\_, Tank 3 \_\_\_\_\_

Working Press: Tank 1 \_\_\_\_\_, Tank 2 \_\_\_\_\_, Tank 3 \_\_\_\_\_

Container(s) to be installed: NEW  USED  BOTH

Information needed to verify container status: Mfg Data Rpt.  Form 23  Form 8

Received:  Date: \_\_\_\_\_

Distance from proposed container(s) to: (check if distance listed meets requirement)

Nearest Highway or Public Street \_\_\_\_\_'

Bulkhead \_\_\_\_\_'  (10') 9.143(e)(4)

Electrical Transmission Line \_\_\_\_\_'  (6') 6.5.3.13

Nearest Building \_\_\_\_\_'  Table 6.4.1.1 \_\_\_\_\_'

Other type fuel container (gasoline) \_\_\_\_\_'  (20') 6.5.3.6

Adjacent LPG Container \_\_\_\_\_'  Table 6.4.1.1 \_\_\_\_\_'

Property Line – N \_\_\_\_\_'  S \_\_\_\_\_'  E \_\_\_\_\_'  W \_\_\_\_\_'  Table 6.4.1.1 \_\_\_\_\_'

NOTIFICATION STATUS (9.102) Applicable YES  NO

**Certified** Survey Plat (**with 500' radius marked**) Rec'd:  Date \_\_\_\_\_

Real property owners listed on survey plat or separate list indicating property owned rec'd?

YES  NO  Date \_\_\_\_\_

LPG Form 500a('s) rec'd:  Date \_\_\_\_\_

Number of **real** property owners: \_\_\_\_\_ Number of owners **properly** notified: \_\_\_\_\_

Certified mail receipts rec'd:  Date \_\_\_\_\_

Latest date notification sent: \_\_\_\_\_

Property owner's (18 day) Response deadline: \_\_\_\_\_

RENOTIFICATION INFORMATION (if required) Applicable YES  NO

Certified mail receipts rec'd:  Date \_\_\_\_\_

Green return receipts cards rec'd:  Date \_\_\_\_\_

Latest date notification rec'd: \_\_\_\_\_

Property owner's (18 day) Response deadline: \_\_\_\_\_

Number of objections rec'd \_\_\_\_\_ Number of owners with **valid** objections \_\_\_\_\_

Valid objection reasons stated: \_\_\_\_\_

INSTALLATION SITE PLAN (check if distance listed meets requirement)

Site plan submitted?

Container location indicated?

Location & distances to Bulkhead: Listed?  Distance \_\_\_\_\_'  9.143(e)(4) – 10'

Container to Elec. Tran. Lines: Listed?  Distance \_\_\_\_\_'  6.5.3.13 – 6'

Container to other type fuel containers: Listed?  Distance \_\_\_\_\_'  6.4.5.5 – 20'

Container to bldg's & structures: Listed?  Distance \_\_\_\_\_'  Table 6.4.1.1 – \_\_\_\_\_' ←↓

Container to property lines: Listed?  N \_\_\_\_\_'  S \_\_\_\_\_'  E \_\_\_\_\_'  W \_\_\_\_\_'

Location & distances to Remote ESV: Listed?  Distance \_\_\_\_\_'  9.143(i) – \_\_\_\_\_ - 100'

Container to Roadway ROW: Listed?  Distance \_\_\_\_\_'

Container to Hwy ROW: Listed?  Distance \_\_\_\_\_'

Container to Railroad: Listed?  Distance \_\_\_\_\_'

Container to Pipeline: Listed?  Distance \_\_\_\_\_'

Route of vehicular traffic around container: Listed?

Location & distances of any electrically operated material handling equipment (pumps, compressors, etc) :

Listed?  Distance \_\_\_\_\_'  Table 6.4.4.3.

Adjacent Container's in Multi-container installation: Listed?  Distance \_\_\_\_\_'  Table 6.4.1.1 \_\_\_\_\_'

Does the installation include a transfer system? YES  NO  *If the point of transfer of containers located outdoors in stationary installations is not located at the container, it shall be located in accordance with Table 6.7.2.1 Point of transfer is defined as The location where connections and disconnection are made or where LP-gas is vented to the atmosphere in the course of transfer operations. (3.3.60)*

If Yes, then the following apply per Table 6.7.2.1:

Is the location of the point of transfer shown, including distance from BH/container? YES  NO

Buildings with fire-resistive walls: Distance \_\_\_\_\_'  (10')\*

Buildings with other than fire-resistive walls: Distance \_\_\_\_\_'  (25')\*

Building wall openings or pits at or below point of transfer: Distance \_\_\_\_\_'  (25')\*

Line of adjoining property that can be built upon: (25')\*

N \_\_\_\_\_'  S \_\_\_\_\_'  E \_\_\_\_\_'  W \_\_\_\_\_'

Outdoor places of public assembly: Distance \_\_\_\_\_'  (50')\*

Public Ways (streets, thoroughfares, sidewalks): Distance \_\_\_\_\_'  (25'\* or 10' for vehicle fuel dispensers)

Driveway: Distance \_\_\_\_\_'  (5') *Does not include vehicle fuel dispensers*

Railroad track centerlines: Distance \_\_\_\_\_'  (25')

Containers other than those being filled: Distance \_\_\_\_\_'  (10')

Flammable & Class II combustible liquid dispensers: Distance \_\_\_\_\_'  (10') See NFPA 30

Flammable & Class II combustible liquid containers: Distance \_\_\_\_\_'  (20')

Electrically Classified areas (see Table 6.25.2.2)\*See 6.7.3.4 The distances shall be reduced by 1/2 where the system incorporates the provisions of low emission transfers in 6.30.5 –

Lease agreement required: YES  NO  Date: \_\_\_\_\_

For new facility locations – is facility accessed from a public hwy under jurisdiction of DOT? YES  NO

If yes, then has a statement or permit from DOT been provided? YES  NO  Date: \_\_\_\_\_

Is the installation a Site Built Subdivision or does the piping to be installed leave the property? YES  NO

*If YES, then the installation must comply with CFR 192.1 (Pipeline Safety Rules). The name of the pipeline installer should be obtained and given to Pipeline Safety to verify the items in 192.1 are covered.*

Unusual topographical or geographical features? \_\_\_\_\_

Other activities, features, or safety concerns? \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

**Review of Submitted Application (deficiencies noted & listed below):**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Action Taken: \_\_\_\_\_

Current Status of Proposal: \_\_\_\_\_