

Enforcement Orders Signed November 17, 2015

City of Bellville

Docket No. GUD 10397

Rules violated:

Violation No. 1

Requirement: 49 CFR 192.1005

The DIMP plan was not written and implemented per the requirement of 192.1005 by 8/02/2011 or for a gas system put into service or acquired after 8/2/2011, was a DIMP plan written and implemented prior to beginning of operation.

Note: Operator did not have DIMP plan available. This is a repeat from the previous year's inspection in 2013 (evaluation no. 2013-2819)

Penalty collected: \$5,000