

Enforcement Orders Signed June 4, 2019

GUD 10819

City of Bryan

System Name:
ATKINS POWER PLANT, 8"
System ID No.: 431089

Violation Code: 192-625-001

The transmission line(s) listed below was in a Class 3 or 4 location, was not exempt from odorization requirements, and transported unodorized gas.

Requirement: 49 CFR 192.625(b)

| Violation Notes | | | | |
|----------------------|------------------------|-------------------------------|--------------------------------|--|
| <u>Evaluation ID</u> | <u>Violation State</u> | <u>Previous Evaluation ID</u> | <u>Location</u> | <u>Note</u> |
| 20190117 | Uncorrected | | Class 3 areas of this pipeline | A December 7, 2018, Class Location Review of this pipeline confirmed its presence in a Class 3 location, and the gas it is transporting was not odorized. Because the pipeline does not have at least 50% of its mileage in a Class 1 or 2 mileage downstream of the Class 3 location, it is required to odorize the gas being transported through the Class 3 area. |

Penalty collected: \$10,000.00